

# ELECTRONICS REGIONAL TEST LABORATORY (SOUTH)

## TEST REPORT ON: STABILIZER

TEST REPORT NO. ERTL(S)/R/3824	DATE : 29-11-2001	PAGE 03 OF 04
-----------------------------------	----------------------	------------------

### 7. TESTS.

SL NO.	TEST/ CONDITION	SPECIFICATION	RESULT	REMARK
1.	Capacity	4 KVA	Complied	Nil
2.	Out put Voltage (over the input range is 140 to 285 volt at full load)	200 V to 240 V	Complied	"
3.	Input low volt cut off (at no load)	120 Volt	Complied	"
4.	Input high volt cut off (at no load)	290 Volt	Complied	"
5.	Delay	between 2 - 4 min.	Complied	"
6.	Transformer	Toroidal	Complied	"

111

